



## PPG LABORATORY TEST RESULTS CERTIFICATION

### ADHESION

PPG Industries, Inc. certifies the following performance properties for the Duranar® Coil Coating System when applied and baked on properly cleaned and pretreated substrates, according to PPG specifications:

<b>COATING:</b>	DURANAR XL PLUS
<b>TEST:</b>	ASTM D-3359 - Standard Test Methods for Measuring Adhesion by Tape Test
<b>SPECIFICATION:</b>	Test Method B - A lattice pattern with eleven cuts in each direction (90 degree to each other) is made in the film to the substrate. A reverse impact is applied 1.5 x metal thickness in mils to the crosshatched area. Pressure-sensitive #610 3M Scotch tape is applied over the reverse impacted lattice area and then removed rapidly.
<b>RESULTS:</b>	There shall be no flaking and no loss of adhesion of the topcoat and primer from the pretreated substrate, 5B classification.

June 3, 2008